



December 22, 2020

Town of Regina Beach  
P. O. Box 10  
Regina Beach, SK, S0G 4C0

Dear Waterworks Owner/Operator:

**RE: Rescinding Precautionary Drinking Water Advisory – Town of Regina Beach (consumers on 200 Block of Osborne Avenue Only)**

The Water Security Agency, in consultation with the Saskatchewan Health Authority-Regina Office, is advising that the **“Precautionary Drinking Water Advisory” (PDWA)** issued for the Town of Regina Beach’s distribution system (**consumers on 200 Block of Osborne Avenue Only**) has been rescinded, as of December 22, 2020.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The turbidity in the system is within regulatory requirements;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Town of Regina Beach in addressing the advisory.

For further information please do not hesitate to contact the undersigned at (306) 630-8476 or [aleena.james@wsask.ca](mailto:aleena.james@wsask.ca).

Sincerely,

A handwritten signature in blue ink, appearing to read "Aleena James", with a stylized flourish at the end.

WATER SECURITY AGENCY  
Aleena James – E.I.T., M.Eng.  
Environmental Project Officer  
Environmental Services Section - South  
Environmental and Municipal Management Services Division

cc: Greg Holovach, Water Security Agency  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Regina