

May 25, 2026

306-527-6128

Via Email: rbpwud@reginabeach.ca

Town of Regina Beach  
Box 10  
Regina Beach SK S0G 4C0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Town of Regina Beach: Rescinded*

1st St E	100,200,300 blocks	2 <sup>nd</sup> St E	100,200 blocks
Centre St	100,200,300 blocks	Macmurchy Ave	500,600 blocks
Nicoll Lane	600 block	Daly Ave	100,200,300 blocks
Fairchild Ave	100,200,300,400 blocks	Allan Ave	100,200 blocks
Green Ave	100,200,300,400,500,600,700 blocks		

The Water Security Agency, in consultation with Saskatchewan Health Authority is advising that the “Precautionary Drinking Water Advisory” (PDWA) issued by the Water Security Agency for the *Town of Regina Beach*’s water distribution system has been rescinded, effective immediately.

The rescinding of the PDWA was based upon information provided by your operational staff, which included:

- The receipt of two consecutive sets of three (6 total) bacteriological samples collected 24 hours apart from the water distribution system are negative for bacteriological growth.

You may return to normal water quality monitoring requirements as detailed in your Permit to Operate a Waterworks. Thank you for your cooperation during this event. For further information please contact the undersigned at 306-527-6128 or jeff.hindle@wsask.ca.

Sincerely,



Jeff Hindle P.Tech.  
Environment Officer  
Water Security Agency

cc: Don Turner - Manager, Compliance Promotion South, WSA (email)  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Regina Office